

**TABLE III
PCB BULK SAMPLE SUMMARY TABLE
NORTH STONINGTON ELEMENTARY SCHOOL
311 NORWICH-WESTERLY ROAD
NORTH STONINGTON, CONNECTICUT**

SAMPLE DATE	SAMPLE #	SAMPLE LOCATION	SAMPLE DESCRIPTION	RESULTS IN PPM		
				RESULTS	REPORTING LIMIT	AROCOR
8/25/2017	B-I-01	Backpack vacuum cleaner	Dust from vacuum bag	8.000	1.600	1254
8/25/2017	B-I-01D	Backpack vacuum cleaner	Dust from vacuum bag	4.700	0.800	1254
8/25/2017	B-I-02	Stand Up Vacuum Cleaner	Dust from vacuum bag	4.200	0.810	1254
8/25/2017	B-I-03	Rubber Waffle Mat, Room 058	Debris from under mat	1.700	0.170	1254
8/25/2017	B-I-04	Library Room 060	Area Rug	9.000	2.30	1254
8/25/2017	B-I-05	Room 107	Area Rug	2.100	1.80	1248
8/25/2017	B-I-06	Room 106	Area Rug	1.000	0.250	1248
8/25/2017	B-I-07	Room 101	Area Rug	0.750	0.290	1248
8/31/2017	92-S-01	Edge of asphalt in front of Room 058 door	Discrete soil sample at 0" to 3" depth interval	ND	0.370	
8/31/2017	92-S-02	Edge of asphalt in front of Room 091 door	Discrete soil sample at 0" to 3" depth interval	ND	0.390	
8/31/2017	92-S-03	Edge of asphalt, Room 086 North Façade	Discrete soil sample at 0" to 3" depth interval	ND	0.380	
8/31/2017	92-S-04	Edge of asphalt, Room 086 West Door	Discrete soil sample at 0" to 3" depth interval	ND	0.370	
8/31/2017	92-S-05	Edge of asphalt, Room 085 West Door	Discrete soil sample at 0" to 3" depth interval	ND	0.350	
8/31/2017	92-S-06	Edge of asphalt in front of Room 058 door	Discrete soil sample at 0" to 3" depth interval	ND	0.350	
8/31/2017	92-S-07	Edge of asphalt in front of Room 058 SW corner	Discrete soil sample at 0" to 3" depth interval	ND	0.390	
8/31/2017	92-S-07D	Edge of asphalt in front of Room 058 SW corner	Duplicate of 92-S-07	ND	0.360	
9/1/2017	B-RF	AHU for 1965/1968 rest rooms	Return filter	4.500	0.520	1254
9/1/2017	B-MBF	AHU for 1965/1968 rest rooms	Mixing box filter	3.400	0.670	1254
9/1/2017	B-022-01	Room 022 (108)	Carpet (after cleaning)	1.100	0.510	1254
9/1/2017	B-069-01	Room 069 (front entrance)	Carpet (after cleaning)	0.660	0.520	1254
KEY			ANALYTICAL METHOD			
ND = NONE DETECTED			SOXHLET EXTRACTION 3540C & ANALYTICAL METHOD SW846 8082			
Filters on AHUs (1965/1968 restrooms and gym) were replaced by EMCOR on 8-31-2017 after samples were collected. Carpet in Room 022 (108) will be isolated until it can be removed.						