

TABLE II

**PCB WIPE SAMPLE SUMMARY TABLE
NORTH STONINGTON ELEMENTARY SCHOOL
311 NORWICH-WESTERLY ROAD
NORTH STONINGTON, CONNECTICUT**

SAMPLE DATE	SAMPLE #	SAMPLE LOCATION	SAMPLE DESCRIPTION	RESULTS (micrograms)		
				RESULTS	REPORTING LIMIT	AROCLOR
8/25/2017	W-I-1-1	Gymnasium Room 053 - North Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-1D	Gymnasium Room 053 - North Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-2	Gymnasium Room 053 - South Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-3	1st Floor Corridor Room 069 - East Side Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-4	2nd Floor Corridor Room 081 - East Side Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-5	1st Floor Corridor Room 069 - West Side Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-6	2nd Floor Corridor Room 081 - West Side Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-7	Music Room 049 - North Side Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-1-7D	Music Room 049 - North Side Wall Expansion Joint (Con-Test)	Surface wipe after encapsulation	ND	0.2	
8/25/2017	W-I-1-8	Classroom 070 - North Side Wall Expansion Joint	Surface wipe after encapsulation	ND	1.0	
8/25/2017	W-I-2-1	Library 060 - North Wall West Window Sill	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-2-2	Library 060 - North Wall East Window Sill	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-2-3	Science Room 078 - North Wall West Window Sill	Surface wipe after cleaning	5.9	1.0	1254
8/31/2017	W-I2-2-3	Science Room 078 - North Wall West Window Sill (adjacent on sill)	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-2-3D	Science Room 078 - North Wall West Window Sill (adjacent on sill)	Surface wipe after second cleaning	ND	1.0	
8/25/2017	W-I-2-4	Classroom 077 - North Wall West Window Sill	Classroom 077 - North Wall West Window Sill	ND	1.0	
8/25/2017	W-I-2-4D	Classroom 077 - North Wall West Window Sill	Classroom 077 - North Wall West Window Sill	ND	1.0	
8/25/2017	W-I-7-1	Gymnasium Room 053 - Lunch Table Top	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-7-2	Gymnasium Room 053 - Lunch Table Top	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-7-3	Gymnasium Room 053 - Lunch Table Top	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-7-4	Gymnasium Room 053 - Lunch Table Top	Surface wipe after cleaning	1.8	1.0	1254
8/31/2017	W-I2-7-1	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
KEY			ANALYTICAL METHOD			
ND = NONE DETECTED			SOXHLET EXTRACTION 8082			
Notes:	Sampling Area = 100 cm ²					

TABLE II

**PCB WIPE SAMPLE SUMMARY TABLE
NORTH STONINGTON ELEMENTARY SCHOOL
311 NORWICH-WESTERLY ROAD
NORTH STONINGTON, CONNECTICUT**

SAMPLE DATE	SAMPLE #	SAMPLE LOCATION	SAMPLE DESCRIPTION	RESULTS (micrograms)		
				RESULTS	REPORTING LIMIT	AROCLOR
8/31/2017	W-I2-7-2	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-7-3	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-7-4	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-7-5	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-7-6	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-7-7	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/31/2017	W-I2-7-8	Gymnasium Room 053 - Lunch Table Top	Surface wipe after second cleaning	ND	1.0	
8/25/2017	W-I-9-2	Gymnasium Room 053 - Metal Door Threshold East Entrance	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-6-1	Library Room 060 - Table Top	Surface wipe after cleaning	ND	1.0	
8/25/2017	W-I-6-1D	Library Room 060 - Table Top	Surface wipe after cleaning	ND	0.2	
8/25/2017	Blank 1	-	-	ND	1.0	
8/25/2017	W-I-S-1	North Stairwell Room 031 - Rubber Tread	North Stairwell Room 031 - Rubber Tread	ND	1.0	
8/25/2017	W-I-S-2	West Stairwell Room 058 - Stair Tread	West Stairwell Room 058 - Stair Tread	ND	1.0	
FURNISHINGS ROOM 049 (109) AFTER CLEANING						
9/1/2017	W-049-01	Metal file cabinet	Surface wipe sample	ND	1.0	
9/1/2017	W-049-02	Metal channel frame under riser	Surface wipe sample	ND	1.0	
9/1/2017	W-049-03	Piano keys	Surface wipe sample	ND	1.0	
9/1/2017	W-049-03D	Piano keys	Surface wipe sample	ND	1.0	
9/1/2017	W-049-04	Student chair	Surface wipe sample	ND	1.0	
9/1/2017	W-049-05	Music stand	Surface wipe sample	ND	1.0	
9/1/2017	W-049-06	Teacher's desk	Surface wipe sample	ND	1.0	
9/1/2017	W-049-B	Field Blank	Surface wipe sample	ND	1.0	
FURNISHINGS ROOM 070 (209) AFTER CLEANING						
9/1/2017	W-070-01	Student table	Surface wipe sample	ND	1.0	
9/1/2017	W-070-02	Student chair	Surface wipe sample	ND	1.0	
9/1/2017	W-070-03	Student desk	Surface wipe sample	ND	1.0	
9/1/2017	W-070-03D	Student desk	Surface wipe sample	ND	1.0	
9/1/2017	W-070-04	Metal file cabinet	Surface wipe sample	ND	1.0	
9/1/2017	W-070-05	Time kit	Surface wipe sample	ND	1.0	
9/1/2017	W-070-06	Teacher's desk	Surface wipe sample	ND	1.0	
KEY			ANALYTICAL METHOD			
ND = NONE DETECTED			SOXHLET EXTRACTION 8082			
Notes:	Sampling Area = 100 cm ²					

TABLE II

**PCB WIPE SAMPLE SUMMARY TABLE
NORTH STONINGTON ELEMENTARY SCHOOL
311 NORWICH-WESTERLY ROAD
NORTH STONINGTON, CONNECTICUT**

SAMPLE DATE	SAMPLE #	SAMPLE LOCATION	SAMPLE DESCRIPTION	RESULTS (micrograms)		
				RESULTS	REPORTING LIMIT	AROCOLOR
9/1/2017	W-070-07	Computer	Surface wipe sample	ND	1.0	
9/1/2017	W-070-08	Unifex cubes	Surface wipe sample	ND	1.0	
FURNISHINGS ROOM 071 (211) AFTER CLEANING						
9/1/2017	W-071-01	Blue student chair	Surface wipe sample	ND	1.0	
9/1/2017	W-071-02	Round table	Surface wipe sample	ND	1.0	
9/1/2017	W-071-03	Printer	Surface wipe sample	ND	1.0	
9/1/2017	W-071-04	Desk	Surface wipe sample	ND	1.0	
9/1/2017	W-071-05	Metal bookshelf	Surface wipe sample	ND	1.0	
9/1/2017	W-071-05D	Metal bookshelf	Surface wipe sample	ND	1.0	
KEY			ANALYTICAL METHOD			
ND = NONE DETECTED			SOXHLET EXTRACTION 8082			
Notes:	Sampling Area = 100 cm ²					
	Furnishings and contents have been removed from Rooms 049 (109), 070 (209) and 071 (211) for use in other locations.					
SAMPLE DATE	SAMPLE #	Book ID Number	SAMPLE DESCRIPTION	RESULTS (micrograms)		
				RESULTS	REPORTING	AROCOLOR
BOOKS - LIBRARY (060) AFTER CLEANING						
9/1/2017	W-B-01	9/27/1901	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-02	8/20/1901	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-03	92 KIN	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-04	2/1/1901	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-05	299 SHE	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-06	307.72	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-07	971-9004	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-08	F-MAR	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-09	940.916	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-10	974.4H	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-11	F-CUS	Surface wipe sample on front cover	ND	1.0	
9/1/2017	W-B-12	F-DEN	Surface wipe sample on front cover	ND	1.0	
KEY			ANALYTICAL METHOD			
ND = NONE DETECTED			SOXHLET EXTRACTION 8082			
Notes:	Sampling Area = 100 cm ²					
	Books were cleaned with HEPA vacuum and placed on mobile racks in gym.					